

IEC**IECEE**

Ref. Certif. No.

CN51158-M1

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME**CB TEST CERTIFICATE**

Product

Flush Metal Pushbutton and Flush Metal Indicator

Name and address of the applicant

Siemens Electrical Apparatus Ltd., Suzhou
No.455 Zhujiang Road, New District, Suzhou, Jiangsu
Province, P.R.China

Name and address of the manufacturer

Siemens Electrical Apparatus Ltd., Suzhou
No.455 Zhujiang Road, New District, Suzhou, Jiangsu
Province, P.R.China

Name and address of the factory

Siemens Electrical Apparatus Ltd., Suzhou, Tiantai Branch
No.699-10 Jigong Road, Tiantai County, Zhejiang Province,
P.R.China*Note: When more than one factory, please report on page 2*

Ratings and principal characteristics

See the Appendix

Trademark (if any)

APT

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

FM22E, FM22N, FM22S, FM22L;

Additional information (if necessary may also be reported on page 2)

Original CB certificate No. is CN51158, dated 2020-08-27.
The issuance of the M1 certificate is to increase different products.

A sample of the product was tested and found to be in conformity with

IEC 60947-5-1:2016(4th Edition); IEC 60947-1:2007; IEC
60947-1:2007/AMD1:2010; IEC 60947-1:2007/AMD2:2014

As shown in the Test Report Ref. No. which forms part of this Certificate

00901-CB2020CQC-091849-M1

This CB Test Certificate is issued by the National Certification Body

CHINA QUALITY CERTIFICATION CENTRE

Section 9, No. 188 Nansihuan Xilu, Beijing 100070 P. R. China

Tel: +86-10-83886666 Fax: +86-10-83886282

website: <http://www.cqc.com.cn>

Date: Feb.22,2024

Signature:

Xie ZhaoXu



FM22E, FM22N, FM22S, FM22L ;
Ui: FM22E, FM22N,
FM22L: 250V,
FM22S: 25V;
Uimp: FM22E,
FM22N, FM22L:
2.5kV, FM22S: 0.5kV;
Ith: FM22E, FM22N:
5A, FM22S: 2A;
FM22E, FM22N:
AC-15: Ue/Ie: 220V/0.5A, 110V/1A, 24V/3A,
DC-13: Ue/Ie: 220V/0.1A, 110V/0.2A, 24V/0.7A;
FM22S:DC-12: Ue/Ie: 24V/0.3A;
IP Code:
Flush metal Pushbutton
(head):
FM22E/N/S: IP65(Except FM22N keylock switch: IP54, selector: IP40),
Flush metal Indicator
(head): FM22L: IP67;
Mounting hole diameter: Φ 22mm


Page 1 of 1

Additional information (if necessary)

Date:

Feb.22,2024

Signature:



Xie ZhaoXu